



Guide to Houses in Multiple Occupation Hostels and Staff Accommodation

Introduction

General Information

The Housing Act 2004 places a duty on the Council to inspect and improve houses in multiple occupation (HMOs). Residential Environmental Health Officers inspect HMOs on a regular basis and respond to housing condition complaints.

What is a HMO?

The full definition of a HMO is found in sections 254 to 260 of the Housing Act 2004. In broad terms a HMO can be described as follows:

An HMO is a building or part of building (flat) which is:

- Occupied by more than one household (which is defined as occupiers of the same family and includes spouses, co-habitees, same sex couples and any blood relative).
Where:
 - At least one of the households shares or lacks access to a basic amenity (These include bedsit type properties, houses partly converted into self-contained flats and bedsits, hostels, accommodation above shops and shared houses and flats) or
 - The building is fully converted into self-contained flats or studios and the conversion work does **not** fully comply with the building standard of the 1991 Building Regulations AND less than 2/3rd of the flats are occupied by long leaseholders.

(Basic amenities means a WC, personal washing facilities and cooking facilities)

We aim to:

- Provide information and advice in plain language about the legislation we apply to HMOs.
- Discuss general issues and specific problems with anyone experiencing difficulties.
- Provide a courteous, efficient and helpful service.
- Actively seek the views of those that receive our services and use this information to develop our service.

Officers will contact landlords to discuss the condition and requirements for their HMO property. A clear list of what is needed to be done to comply with legislation and standards applicable to HMOs will be provided.

A statutory notice is often also served, and this requires specified works to be undertaken within a defined time period; this type of notice will also provide details of how to appeal to a residential property tribunal.

If a statutory notice is not complied with the council may prosecute, issue a Civil Penalty and may organise for the work to be done and recharge the cost, plus fees, to the owner of the property.

Housing health and safety rating system (HHSRS)

The Housing Health and Safety Rating System (HHSRS) is a system for assessing the health and safety risks in dwellings, and is a method used to inspect properties in Westminster. A HMO can comprise of a number of separate dwellings, for example every bedsit room or self-contained flat within a HMO is a dwelling.

The principle of HHSRS is that any residential premises (including the structure, means of access, and any associated outbuilding, garden or yard) should provide a safe and healthy environment for any potential occupier or visitor. HHSRS is a risk assessment process and is comprehensive in its coverage of key health and safety risks in dwellings. In very broad terms, the rating system works by assessing the risk associated with certain home hazards and if the likelihood of harm is significant the council may take action to ensure that the risk is removed or reduced.

For a fuller explanation of HHSRS contact the Service, details of which are on Page 12.

HMO LICENSING

Certain categories of HMO must be licensed by the Council. Licensing aims to improve conditions and management within HMOs by ensuring:

- Conditions within a HMO comply with the Council's HMO standards.
- Landlords and/or their agents can be considered as 'fit and proper' persons as defined in the Housing Act 2004.
- Management arrangements for the HMO are appropriate.

Information concerning HMO licensing and how to apply online can be found at: <https://www.westminster.gov.uk/houses-multiple-occupation>

How to use the HMO guides

Residential Environmental Health has produced four guides for each of the following types of HMO:

- HMOs comprising bedsits/studio rooms.
- HMOs comprising self-contained flats.
- Flats in multiple occupation (FMOs) where flats are multiply occupied by more than one household.
- Hostel/staff accommodation.

Some properties will have a mix of accommodation and more than one of the guides will apply.

Application of this standard

Hostels must have appropriate planning consent for lawful operation as a hostel and cater for a specific group or groups of occupiers

For example

- Long term vulnerable residents
- Short term vulnerable residents
- Privately managed student accommodation
- Privately managed nurses accommodation
- Homeless persons
- Staff accommodation provided in connection with employment.

Hostels may provide some meals or welfare arrangements to the occupiers and have on site management.

In respect of temporary winter shelters for the street homeless, provided by other government departments, a flexible approach will be adopted, with priority given to the management, hygiene and health and safety issues within these properties.

Room sizes for hostels

Maximum number of people	Minimum size of bedroom room
1	Not less than 6.51 m ²
2	Not less than 10.22 m ²
3	Not less than 13.40 m ²
4	Not less than 16.50 m ²
5	Not less than 19.60 m ²
6	Not less than 22.70 m ²
	And 3.1 m ² per additional person.

Note: Where a bedroom is used for both sleeping and cooking, a minimum of 3.7m² shall be added to the minimum bedroom floor area.

Guidance on taking measurements:

Only **practical useable living space** must be measured. This space:

- Does not include any area taken up by bathroom facilities within the room.
- Does not include the chimney breast and small alcoves.
- Does not include the floor area where the ceiling height is less than 1.9 metres, or in addition, in attic rooms, any floor area in the eaves of the room where the soffit height is less than 1.5 metres.
- Does not include any fire lobby or bathroom lobby.

In calculating practical living space, the following can be taken into account:

- If a studio room has a partition, the floor area of both rooms can be included.
- In hostels rooms less than the minimum area permitted of 6.51m² cannot be used for sleeping.
- Half the area provided by a bay window can be included.
- Entrance lobbies/corridors within bedrooms. Where the room door opens into a lobby/corridor that is less than 1.2 metres wide, the entire lobby/corridor should be discounted. Where the lobby/corridor is between 1.2 and 1.8 metres, some of the area may be counted (this reflects the fact that wider corridors are able to make a contribution to the storage capacity and spaciousness of bedrooms. The allowable area is calculated by deducting 1.2 metres from the width and multiplying this by the length of the corridor. For example, if a corridor into a room is 1.5 metres wide by 2.5 metres deep, the useable area of the corridor would be (1.5 – 1.2 =) 0.3 x 2.5 metres. No deduction should be made where doors open into corridors/lobbies of more than 1.8 metres width.

Occupation

- 2 tier bunk beds are permitted providing the ceiling height is greater than 1.5m, and the permitted number stated on page 3 above is not exceeded.

Facilities for the storage, preparation and cooking of food

Exclusive Facilities

Whenever practicable hostels should provide food preparation/cooking/storage facilities which are for the exclusive use of each household, these facilities must comply with the standard described below.

Where any **family with children** is in occupation, kitchen facilities shall be provided for their **exclusive use** in accordance with the standard below.

- An oven, grill, and at least 4 hobs. (In single bedrooms 2 hobs, oven and grill or 2 hobs and a combination microwave are acceptable). Cookers must not be sited adjacent to exit doors.
- A tiled surface as a cooker splashback; a lift-up cover to the appliance would be a suitable alternative.
- A suitable sink and integral drainer (minimum size 1000mm x 500mm) (or alternatively a dual sink) set on a base unit. The sink is to be provided with constant and adequate supply of hot and cold water and properly connected to the drainage system. A tiled splashback (minimum 300mm high) shall be provided to the sink and drainer.
- A fixed worktop, in addition to the drainer - minimum size 1000mm x 600mm, and provided with a tiled splashback (minimum 300mm high).
- A storage cupboard, minimum capacity 0.4 cubic metres (15 cubic feet). The storage space below the sink unit cannot be used for food storage.

A fridge **with** freezer compartment - minimum size 4.5 cubic feet with adequate freezer space.

- 4 (13 amp) electric sockets in the food preparation area. At least 2 of these sockets to be above worktop level.

The food preparation/cooking/storage area must comply with the following:

- Floor covering must be hard wearing and washable.
- There must be adequate mechanical ventilation, where practicable.
- Any mechanical ventilation provided to the kitchen area should be via an extract cooker-hood vented to the external air.
- There must be artificial lighting sufficient to carry out normal activities within a kitchen area.
- Kitchens provided in a separate room must be adequate in size, and in any case not less than 5.5m², and be so arranged to allow safe access and use.
- Kitchen facilities must be suitably located to allow the occupants to adequately store, prepare and cook their food.
- Kitchens must not be installed in any hallway, corridor or lobby.

Shared facilities

In circumstances where the Council is satisfied that exclusive use facilities cannot be provided, shared kitchens providing facilities for the preparation and cooking of food may be provided.

Some examples of properties where this would be considered acceptable are:

- Long term hostels for vulnerable persons, e.g. Church Army, Housing Associations, Voluntary Welfare Societies, where there is an element of supervision and communal living, as part of a welfare role.
- Group Homes occupied by a defined group of residents, with special needs. If sharing is to be permitted the organisation responsible must demonstrate that there is a need for sharing of amenities and that there is proper supervision/control and management at the property.

Each shared kitchen shall be provided with a set of food preparation/cooking/storage facilities at a ratio of at least 1 set of facilities per 5 occupiers. There should be no more than 2 sets of facilities within a kitchen, situated not more than one floor distant from each user.

Each set of facilities for the preparation, cooking and storage of food should comprise the following:

- An oven, grill, and at least 4 hobs. Cookers must not be sited adjacent to exit doors.
- A tiled surface as a cooker splash back; a lift-up cover to the appliance would be a suitable alternative.
- A suitable sink and integral drainer (minimum size 1000mm x 500mm) set on a base unit. The sink is to be provided with constant and adequate supply of hot and

cold water and properly connected to the drainage system. A tiled splashback (minimum 300mm high) shall be provided to the sink and drainer.

- A fixed worktop, in addition to the drainer - minimum size 1000mm x 600mm, and provided with a tiled splashback (minimum 300mm high).

Food storage should normally be provided in individual bedrooms but in certain circumstances food storage cupboards may be provided in the shared kitchen. If the food storage cupboard is provided in the kitchen it must be:

- Exclusive to each household
- Minimum size of 600mm x 500mm x 600mm • Secured against unauthorised access.
- The storage space below the sink unit cannot be used for food storage.
- In addition to the fridges provided in the individual bedrooms, an additional fridge must be provided in the shared kitchen.
- 4 (13 amp) electric sockets in the food preparation area. At least 2 of these sockets to be above worktop level.

The food preparation/cooking/storage area must comply with the following:

- Floor covering must be hard wearing and washable.
- There must be adequate mechanical ventilation, where practicable.
- Any mechanical ventilation provided to the kitchen area should be via an extract cooker-hood vented to the external air.
- There must be artificial lighting sufficient to carry out normal activities within a kitchen area.
- The kitchen must be adequate in size, and in any case must not be less than 5.5m² and be so arranged to allow safe access and use.
- Kitchen facilities must be suitably located to allow the occupants to adequately store, prepare and cook their food.
- Kitchens must not be installed in any hallway, corridor or lobby.

Room exclusive facilities

The following facilities shall be provided within each bedroom

- A fridge minimum size 4.5 cubic feet with adequate freezer space
- A food storage cupboard, minimum size 600mm x 500mm x 600mm

Meal provision

The Council requires either the provision of kitchen facilities exclusive to each household or shared kitchens at a minimum ratio of one set of kitchen facilities to five occupiers, as specified above. However, in certain circumstances the Council will consider a relaxation of this standard, where there is an element of meal provision within the property.

The extent to which standards may be relaxed will depend on factors including the extent of meal provision, the location of meal provision facilities and dining areas, and the nature of the tenant group using the facilities.

Meal provision can range from a full refectory service located on-site providing 3 meals a day which are sufficient and suitable for the occupants, to limited meals provided on a less frequent basis, or located in an off-site facility (e.g. More than 5 minutes walk away). Examples of the type of hostel providing full refectory service are those run by charities such as the Salvation Army, or staff/nurses accommodation, where meals are provided at a subsidised rate or as part of their employment conditions.

In any case, the provision of kitchen facilities for occupants must meet national minimum standards for houses in multiple occupation. This will require the additional provision of separate kitchen facilities for the use of occupants outside of meal service times.

These facilities must be in a sufficient quantity for the numbers of occupants sharing them bearing in mind the extent of the meals provided (e.g. Full refectory service will only require limited additional kitchen facilities, similar to office 'teapoints').

The minimum standards to be met are;

- A sink with draining board
- Adequate supply of cold and constant hot water to each sink supplied
- Installation of equipment for the cooking of food-combination microwave ovens are recommended.
- Electrical sockets
- Worktop for the preparation of food
- Cupboards for the storage of food or kitchen and cooking utensils
- Refrigerators with an adequate freezer compartment (or, where freezer compartment is not adequate, adequate separate freezers)
- Appropriate refuse disposal facilities
- Appropriate extractor fans, fire blankets and fire doors

In some cases it may be preferable to provide the following facilities within each bedroom in addition to the shared facilities;

- A fridge of minimum size of 4.5 cubic feet with adequate freezer space
- A food storage cupboard, of minimum size 600mm X 500mm X 600mm)

In deciding the quantity of kitchen facilities to be provided each case will be judged on it's own particular merits.

Additional kitchen facilities provided must also meet the following conditions where practicable;

- Be not more than one floor distant from the majority of users

- Be not more than 2 floors distant from any user

For staff working in public houses/restaurants and living on the premises where meals are provided as part of an employment contract the following conditions must be met;

- Shared kitchen facilities must be provided separately from any commercial kitchen on the premises
- Where there are also “non-staff” residents, facilities exclusive to these lettings must be provided within the lettings

WC and Bath/Shower Facilities

A **separate WC in its own compartment must be provided**, not being more than one floor distant from each user, and provided at a ratio of not less than one WC per five persons, irrespective of age.

(Note: Any WC within a bathroom will not be included for counting purposes as there must be a separate WC compartment)

Bath/shower

A bath (minimum dimensions 1600mm x 700mm) or shower (minimum dimensions 800mm x 800mm) with constant and adequate supply of hot and cold water, and properly connected to the drainage system, not being more than one floor distant from each user, should be provided at a ratio of not less than one bath or shower per five persons, irrespective of age.

Each WC (whether within its own compartment or within a bathroom) must have:

- Adequate ventilation and artificial lighting.
- Adequate size and layout.
- A suitable wash hand basin, minimum size 500mm x 600mm, provided with constant and adequate supply of hot and cold water and properly connected to the drainage system.
- A tiled splashback (minimum 300mm high) shall be provided to the wash hand basin.
- An appropriate door which is lockable and ensures privacy for the user.

Each shower room/bathroom must be provided with the following :

- A tiled splashback (minimum 450mm high) to the bath.
- If an over bath shower is provided then the adjacent walls should be fully tiled.
- A fully tiled shower or the shower must be in a purpose built shower cubicle, with a suitable water resistant shower curtain or door to the cubicle.
- Adequate heating, ventilation and artificial lighting.
- A suitable and washable floor covering, sealed at its edges.
- An appropriate door which is lockable and ensures privacy for the user.
- Adequate size and layout with adequate space for drying and dressing.

- Each bath or shower room (excluding shower enclosures) must have a wash hand basin, minimum size 500mm x 600mm, with hot and cold water and a tiled splashback (minimum 300mm high).

Wash hand basins within sleeping rooms

- Each sleeping room must have a wash hand basin, minimum size 500mm x 600mm, provided with constant and adequate supply of hot and cold water and properly connected to the drainage system.
- A tiled splashback (minimum 300mm high) shall be provided to the wash hand basin.

Space heating and hot water

An adequate means of space heating must be provided in all rooms, including common parts of the building and bathrooms, taking into account affordability, insulation, ease of use and performance.

Where space heating and hot water are provided centrally by the landlord, these services should be made available at all times. There must also be the ability to control the level of heating within each letting.

Security

It is necessary that consideration is given to the security of the property and appropriate measures are taken to prevent 'Entry by Intruders' hazards.

Communal Exterior Doors

- Exterior doors to the front and rear should be able to close fully and be capable of resisting bodily pressure and the possibility of slipping the door lock.
- Exterior doors must be fitted with a self-closer with enough force and momentum to ensure that the door closes securely.
- The door and surrounding frame should be of a solid construction.
- Any lock fitted should comply with BS 8621 (2007) for keyless egress.
- Solenoid based, bolt action locks are acceptable and preferred, as they comply with means of escape requirements. They also offer the advantage of requiring less maintenance.
- Where the front door lock is within arm's reach of the letterbox, then either a letterbox cowl or a bottomless cage should be fitted.
- Consideration of the glazing for and surrounding the door should be given. Single glazed panels should be either protected with metal grilles or replaced with laminated glazing or security film.

Bedsit and Flat Entrance Doors

- The door and surrounding frame should be of a solid construction.

- They require an Auto-Deadlocking Nightlatch complying with BS 8621 (2007).
- They require a Mortice lock with thumb turn cylinder complying with BS 8621 (2007), in order to aid escape in the event of a fire.
- The door needs to be fitted with hinge bolts and frame reinforcers (eg, London Bar) to resist bodily pressure.
- Door chains and viewers are required.
- Where there are letterboxes to individual flats a letterbox cowl or bottomless cage is required if the lock is within arm's reach of the letterbox.

Windows

- All windows should have key operated locks with the exception of windows which are complying with fire regulations as part of a means of escape.
- Where windows don't have a lock in order to comply with fire regulations (eg, green button handle locks), then they must be either double glazed units or laminated glazing or fitted with a security film or have a metal grill. The window will also require a security latch.
- Windows for basement, ground floor or 1st floor dwellings that lead directly to a flat roof require restrictors to be fitted.
- Any glazed area within a window below 800mm from floor level must be safety glass in case of collision.

Means of escape in case of fire

A House in Multiple Occupation must be provided with an adequate means of escape in case of fire, fire detection and emergency fire fighting equipment. The actual level of provision will be determined by a risk assessment process having regard to the structure & use of the property and appropriate benchmark guidance documents. Please note that separate fire safety legislation applies to the common areas of hmos-the Regulatory Reform (Fire Safety) Order 2005 [the FSO]-this is enforced by the Fire & Rescue Authority. A key part of the FSO is the requirement for a Fire Risk Assessment to be carried out, this has been the case since 2005. Before proceeding to design a scheme of fire safety works you should consult the Fire Risk Assessment for the house.

It is strongly recommended that you discuss your proposals for providing an adequate means of fire safety with a Residential Environmental Health Officer before contractors are engaged or works carried out; our contact details are on page 13.

Common Areas Fire Safety

Provision of a Protected Escape Route

The protected escape route leads from the letting to the street exit through the building, and normally includes staircases, passageways, landings and protected lobbies. Protection is provided by fire doors and partitions with varying degrees of fire resistance. The Building

Regulations benchmark provision is 60 minutes fire resistance for partitions & floors. In most existing houses this will not be possible and lesser fire resistance of 30 minutes will be accepted with appropriate automatic fire detection. A partition constructed of lath and plaster, in sound condition, with appropriate automatic fire detection will be deemed to satisfy this requirement. The protected escape route must be kept clear of rubbish, furniture and other stored items.

Stairway Protection

Ideally more than one escape stairway should be provided, although this can rarely be achieved in existing houses; houses with more than 4 stories are subject to additional provisions and restrictions.

Note that a storey is any floor above and including the ground floor.

Six storey (or more) buildings require more than one escape stairway, the additional stairway may be external. As an alternative a single escape stairway would be acceptable if provided with a secondary upwards means of escape from within the single stairway and lobby protection to the stairway.

Five storey buildings require lobby protection to the single stairway. This may be waived if a secondary upwards means of escape is provided from within the stairway (as for a six storey building above).

Lobby protection is for smoke control purposes, to prevent smoke from a dwelling fire entering the escape stairway. Protected lobbies provide an additional fire resisting self-closing door between the dwelling and the stairway; the lobby partitions must be 30 minute fire resisting.

Stairway partitions, including floors separating stairways from dwellings, must provide at least 30 minutes fire resistance. If it is desired to regard a basement flat as a separate residential premises (and not requiring a linked fire alarm) the flat must not be linked to the ground floor hallway and the separating ceiling/floor partition must meet the building regulations 60 minute fire resistance requirement.

Commercial areas of the building should not share the residential escape stairway. The separating partitions, including ceiling/floors where appropriate, should be imperforate and provide 60 minutes fire resistance.

If the separating partitions do not meet these requirements the extension of the common areas fire detection system into the commercial parts of the building is likely to be required. Any door opening from a commercial area onto the residential stairway must provide 60 minutes fire resistance; lobby protection may be required in some cases and is generally preferable. When considering the provision of lobby protection regard should be had to the fire risk & fire loading of the commercial area together with the practicality of installation.

Fire resistant doors are required to all doors opening onto the protected route. The fire doors must provide at least 30 minutes fire resistance under BS 476 test conditions, and must be

provided with intumescent fire seals and cold smoke seals. Fire doors must be fitted with an effective self-closing device (except storage cupboards, which should be locked shut).

Any lock fitted to a door used as a means of escape (including the street door) must not require a key to open it from the inside when locked, in order to allow escape in the event of a fire. The provision of a 'thumb turn' release on the inside will be required. Where such doors are fitted with electronic access controls and/or locks please see Local Government Association 'Fire Safety in Purpose-built Blocks of Flats' guide for recommendations.

Automatic Fire Detection (AFD) System

Provision of any form of AFD system requires specialist advice to design and install the system correctly. Hostels and staff accommodation covers a wide range of property types and uses requiring different AFD system designs. Where intended for occupation as sheltered or supported housing for vulnerable residents the National Fire Chiefs Council's 'Fire Safety in Specialised Housing' guide should be consulted. In general terms, for accommodation configured as bedsit units, the installation of a 'mixed grade' system, in accordance with BS 5839 Part 6 will be required.

This type of system is designed to provide the earliest possible warning of a fire within a dwelling [letting] or the common parts whilst minimising instances of false/nuisance alarms affecting more than one dwelling.

In practice, a typical bedsit/studio room property will require:-

- A grade A system providing smoke detection to the protected escape route and to any cupboards in the stairway, together with manual call points. Smoke detectors and call points are normally installed at each landing level. Note that smoke detectors in the stairway should be of the optical type and that multi-sensor detectors that include optical smoke detection are acceptable.
- Installation of heat detectors in individual lettings as part of the grade A system. In some hostels, subject to satisfactory risk assessment & management controls, the Grade A heat detectors may be replaced by Grade A smoke detectors or multi-sensor detectors that include smoke detection. In these cases the 'dwelling' AFD provision may be deleted.
- All detectors that are part of the grade A system are to be wired in circuit so that detection of smoke or heat will automatically activate the alarm throughout the house.
- The system must be regularly inspected and maintained by a competent person as specified in BS 5839.

Emergency Lighting

Emergency lighting which comes on if mains electricity fails must be fitted to illuminate the protected route and some internal staircases, and must be in compliance with BS

5266. Emergency lighting must also be provided to any external escape route or stairway.

Fire Exit Signs

In most average risk residential buildings fire exit signs will not be required. A possible exception is when there is a choice of direction to exit the building in the event of a fire, and when the escape route is not a normal route from the building. This particularly applies when there is a secondary escape route such as an external staircase or another internal staircase. Signs may have to be illuminated (this is not required where they are adequately lit by emergency lighting).

Signs must comply with BS 5499 and the Health and Safety (Safety Signs & Signals) Regulations 1996.

Fire Fighting Equipment

The provision of emergency firefighting equipment forms part of the Fire Risk Assessment for the common areas of the house. Any provision is intended for use by trained operatives only, in the absence of trained staff on site, provision will generally not be required.

Where present, firefighting equipment must be selected, installed, and maintained in accordance with BS 5306. The provision of common parts extinguishers will generally only be required in plant rooms, boiler rooms, and common areas that are places of work.

Dwelling Fire Safety

Dwelling Layout and Design

The positioning of any cooking facilities located within the room must not prejudice escape from the room and should be located away from the room door. The provision of gallery bedspaces may require additional measures to provide a safe means of escape from the gallery level.

Automatic Fire Detection (AFD) System

A linked Grade A heat detector provided as part of the common areas system will provide no protection against a fire originating within the accommodation unit. For this reason a separate Grade D1 mains powered. [with tamper-resistant battery backup] smoke alarm complying with BS EN 14604 must be provided in the bedsit/studio room. Fitting of an optical type smoke alarm is advised. Note that a multi-sensor smoke alarm incorporating optical smoke detection is acceptable. Multi-room lettings will require additional provision.

Care should be taken to ensure that the test/hush buttons of the alarm can be safely operated from floor level-this may be a problem where the alarm is fitted on a high ceiling. The ability to access alarm control buttons is essential, and fitting of remote test/hush controls at low level may be required.

Note that the dwelling smoke detection function may be incorporated in the 'common parts' Grade A system, subject to a suitable risk assessment. In these cases fitting of a separate dwelling smoke alarm will not be required.

Fire fighting equipment

In the event of a fire residents should evacuate to a place of safety and not put themselves at risk or delay their evacuation to fight a fire. There will be some circumstances where residents are capable of using either fire blankets or multi-purpose fire extinguishers in the very early stages of a fire and, providing they do not put themselves or others at risk, prevent a fire from developing. The following provisions should be provided within the dwelling, where it contains a kitchen:

- A fire blanket, to comply with BS 6575, must be provided in the kitchen
- A 1 litre multi-purpose extinguisher suitable for use on electrical fires. Dry powder extinguishers are not recommended for use in the home therefore a foam extinguisher, tested for limited electrical use should be provided in accordance with BS 5306.

Gas Safety & Carbon Monoxide

Landlord's gas safety certificates should be provided to tenants in relation to gas appliances within their accommodation. All appliances are to be kept in good repair and working order, having regard to observations made on the safety certificate. Combustion appliances located within rooms used for sleeping purposes present an increased risk of Carbon Monoxide poisoning if the appliance/flue malfunctions or is misused.

A Carbon Monoxide alarm, complying with the provisions of BS EN 5091:2001 and fitted in accordance with the manufacturer's instructions, must be provided in all rooms containing a combustion appliance of any type.

Listed buildings

Fire protection works within listed buildings requires more specialist consideration and building techniques, and you are strongly advised to contact the Listed Building section of the Planning Department before commencement of any works. Contact telephone number 020 7641 2513.

Planning consent

Compliance with these standards does not confer planning approval for any particular use; contact the Planning Department for further advice. Contact telephone number 020 7641 2513.

HMO Management

[The Management of HMOs Regulations 2006](#) apply to hostels that require a mandatory HMO licence and detail full responsibilities of managers and occupiers. Failure by a manager to comply with the regulations may result in prosecution or a fixed penalty up to £30,000 per offence.

Responsibilities of the Manager – the manager must ensure that:

- The manager's name, address and any telephone contact number is made available to each household in the HMO and these details must be clearly displayed in a prominent position in the HMO.
- Each letting is in a clean condition at the beginning of any rental period and that the internal structure, fixtures/fittings/appliances, windows and mechanical ventilation are maintained in good repair and clean working order.
- All common parts i.e. Staircases, passageways, corridors, halls, lobbies, entrances, balconies and steps are maintained in good and clean decorative repair, in a safe and working condition and kept reasonably clear from obstruction.
- Outbuildings, boundary walls, yards and fences are maintained in repair, clean condition and good order. The garden must be kept in a safe and tidy condition.
- The water supply is constant and not unreasonably interrupted and that the drainage system serving the HMO is maintained in good, clean and working condition.
- Annual gas safety tests are carried out on all gas appliances within the HMO by a Gas Safe registered engineer, and evidence is supplied to support this if requested by the Council.
- The electrical installation is inspected and tested at intervals not exceeding five years by a person qualified to undertake such inspection and testing, and evidence is supplied to support this if requested by the Council.
- The gas or electricity supply, used by any occupier within the HMO, is not unreasonably interrupted.
- All means of escape from fire, any automatic fire detection system and fire fighting equipment are maintained in good working order and are kept free from obstruction.
- All reasonable steps are taken to protect the occupiers of the HMO from injury, ensuring structural safety within the HMO, and that windows set close to or at floor level are suitably safeguarded.
- Sufficient bins or other suitable receptacles are provided for the storage of refuse and litter pending their disposal.

Responsibilities of the Occupier – the manager must ensure that:

- Reasonable access is provided into their letting in order for the manager to undertake any work required under the management regulations.
- Reasonable care is taken to avoid damage to any items which the manager has responsibility to supply, maintain or repair under the management regulations.
- Litter is stored and disposed of in accordance with arrangements made by the manager under the management regulations.
- Reasonable instructions from the manager, in respect of any means of escape from fire, the prevention of fire and the use of fire equipment, are complied with.

Other Management Issues

Furniture and Furnishings (Fire)(Safety) Regulations 1998 (amended 1989 & 1993)

- Furniture and furnishings supplied in conjunction with the accommodation must comply with specified levels of fire resistance.

Gas Safety (Installation and Use) Regulations 1998 (amended 2018)

- Gas safety inspections and tests must be completed by a Gas Safe registered gas installer/engineer annually. Certificates are required in relation to ALL gas appliances and the gas installation.
- All servicing and repairs are to be carried out by Gas Safe approved contractors.
- Records of annual safety inspections and tests must be made available to the Council for inspection, with a copy supplied to the tenant.

Service contact details

Address:

Westminster City Council
Public Protection & Licensing
Westminster City Hall
64 Victoria Street
London
SW1E 6QP

Tel: 020 7641 6161

Email: HMO@westminster.gov.uk

Web: <https://www.westminster.gov.uk/houses-multiple-occupation>